

Clarification

September 20, 2017

To: Trade Package 15B- HVAC Bidders

Re: Clarification, Dated September 20, 2017
New Pierce County High School- Pierce County Board of Education

The following is offered on Trade Package 15B - HVAC

Clarification

1. Outdoor airflow monitoring stations, as noted on the rooftop unit schedule note 18, should be priced, provided, and installed by the mechanical subcontractor under the equipment package. These can be integral with the rooftop equipment or as a separate add on but they must be provided and installed as part of the mechanical subcontractor's scope of work.

The airflow stations should be wired under the scope of the controls contractor and integrated into the building automation system for functionality of the rooftop units. This can be found in the controls specification section 230923, Part 4, section 4.1, paragraph A, item 6: Outdoor air velocity sensor (outdoor air velocity sensor and outdoor airflow monitoring station are the same thing).

END OF SECTION

Bids are still due on September 21, 2017 by 2:00 pm.